

# Rigid PVC Conduit - Schedule 40

Listed to UL 651

## Schedule 40 Rated for use with 90° C Wiring



Schedule 40 is sunlight resistant. Meets or exceeds the requirements of NEMA TC 2 and UL 651 for Schedule 40 Conduit.

Trade Size	Part Number	Average O.D. (in)	Minimum Average I.D. (in)	Minimum Wall (in)	Weight Per Foot (lbs)	10 Ft Crate Quantity (ft)
1/2	8102	0.840	0.578	0.109	0.165	6000
3/4	8103	1.050	0.780	0.113	0.220	4400
1	8104	1.315	1.004	0.133	0.326	3600
1-1/4	8105	1.660	1.335	0.140	0.441	3300
1-1/2	8106	1.900	1.564	0.145	0.528	2250
2	8108	2.375	2.021	0.154	0.730	1400
2-1/2	8110	2.875	2.414	0.203	1.158	930
3	8112	3.500	3.008	0.216	1.609	880
3-1/2	8114	4.000	3.486	0.226	1.935	630
4	8116	4.500	3.961	0.237	2.292	570
5	8120	5.563	4.975	0.258	3.105	380
6	8124	6.625	5.986	0.280	4.030	260
8*	—	8.625	7.853	0.322	6.065	140

\* UL 651 does not include 8"



## Schedule 40 Rated for use with 90° C Wiring



Schedule 40 is sunlight resistant. Meets or exceeds the requirements of NEMA TC 2 and UL 651 for Schedule 40 Conduit.

Trade Size	Part Number	Average O.D. (in)	Minimum Average I.D. (in)	Minimum Wall (in)	Weight Per Foot (lbs)	20 Ft Crate Quantity (ft)
1/2	8502	0.840	0.578	0.109	0.165	12000
3/4	8503	1.050	0.780	0.113	0.220	8800
1	8504	1.315	1.004	0.133	0.326	7200
1-1/4	8505	1.660	1.335	0.140	0.441	6600
1-1/2	8506	1.900	1.564	0.145	0.528	4500
2	8508	2.375	2.021	0.154	0.730	2800
2-1/2	8510	2.875	2.414	0.203	1.158	1860
3	8512	3.500	3.008	0.216	1.609	1760
3-1/2	8514	4.000	3.486	0.226	1.935	1260
4	8516	4.500	3.961	0.237	2.292	1140
5	8520	5.563	4.975	0.258	3.105	760
6	8524	6.625	5.986	0.280	4.030	520
8*	—	8.625	7.853	0.322	6.065	280

\* UL 651 does not include 8"



Item availability may vary by region.

NOTE: Special orders are non-cancelable, non-returnable and non-refundable.

[www.alliedeg.com](http://www.alliedeg.com)

**allied**  
TUBE & CONDUIT®

A PART OF **atkore**  
INTERNATIONAL

# Rigid PVC Conduit - Schedule 80

Listed to UL 651

## Schedule 80 Rated for use with 90° C Wiring



Schedule 80 is sunlight resistant. Meets or exceeds the requirements of NEMA TC 2 and UL 651 for Schedule 80 Conduit.

Trade Size	Part Number	Average O.D. (in)	Minimum Average I.D. (in)	Minimum Wall (in)	Weight Per Foot (lbs)	10 Ft Crate Quantity (ft)
1/2	9302	0.840	0.502	0.147	0.205	6000
3/4	9303	1.050	0.698	0.154	0.278	4400
1	9304	1.315	0.910	0.179	0.410	3600
1-1/4	9305	1.660	1.227	0.191	0.565	3300
1-1/2	9306	1.900	1.446	0.200	0.726	2250
2	9308	2.375	1.881	0.218	1.004	1400
2-1/2	9310	2.875	2.250	0.276	1.531	930
3	9312	3.500	2.820	0.300	2.049	880
3-1/2	-	4.000	3.280	0.318	2.499	630
4	9316	4.500	3.737	0.377	3.122	570
5	9320	5.563	4.713	0.375	4.330	380
6	9324	6.625	5.646	0.432	5.954	260



## Schedule 80 Rated for use with 90° C Wiring



Schedule 80 is sunlight resistant. Meets or exceeds the requirements of NEMA TC 2 and UL 651 for Schedule 80 Conduit.

Trade Size	Part Number	Average O.D. (in)	Minimum Average I.D. (in)	Minimum Wall (in)	Weight Per Foot (lbs)	20 Ft Crate Quantity (ft)
1/2	-	0.840	0.502	0.147	0.205	12000
3/4	-	1.050	0.698	0.154	0.278	8800
1	9504	1.315	0.910	0.179	0.410	7200
1-1/4	-	1.660	1.227	0.191	0.565	6600
1-1/2	-	1.900	1.446	0.200	0.726	4500
2	9508	2.375	1.881	0.218	1.004	2800
2-1/2	-	2.875	2.250	0.276	1.531	1860
3	9512	3.500	2.820	0.300	2.049	1760
3-1/2	-	4.000	3.280	0.318	2.499	1260
4	9516	4.500	3.737	0.377	3.122	1140
5	9520	5.563	4.713	0.375	4.330	760
6	9524	6.625	5.646	0.432	5.954	520



Item availability may vary by region.

NOTE: Special orders are non-cancelable, non-returnable and non-refundable.